



KATHMANDU UPATYAKA KHANEPANI LIMITED
Water / Waste Water Quality Assurance Division , Mahankalchaur
Laboratory Record Of Chemical & Bacteriological Analysis Of Water
Bhadra 2083

S.N	Date	Time	Branch	Location	Sample type	Appearance	Turbidity	Colour	p ^H	Electrical Conductivity	Total Alkalinity	Total Hardness	Total Iron	Total Ammonia	Chloride	F.R.C.	Total Coliforms	Remarks
Units							(NTU)	(TCU)		µs/cm	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	CFU/100 ml	
National Drinking Water Quality Standard (NDWQS)							5	5	6.5-8.5	1500		500	0.3 (3)	1.5	250	0.1-0.5	0 in 95% Samples	
1	2083/05/01	9:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.83	< 5	7.03	47.2	14	16	0.1	0.02	4	1.52	0	Satisfactory
2	2083/05/01	9:52	Lalitpur	Sainbu W.T.P.	Treated	Clear	3.9	<5	7.92	390	96	90	0.1	0.02	18	1.9	0	Satisfactory
3	2083/05/01	13:35	Lalitpur	Sainbu W.T.P.	Treated	Clear	3.85	<5	7.86	388	92	88	0.1	0.02	16	1.5	0	Satisfactory
4	2083/05/01	15:55	Lalitpur	Sainbu W.T.P.	Treated	Clear	3.8	<5	7.82	385	88	80	0.1	0.02	18	1	0	Satisfactory
5	2083/05/01	9:30	Madhyapur Thimi	Bode WTP	Treated	Clear	1.62	<5	7.09	298	98	70	0.19	1.5	18	0.19	0	Satisfactory
6	2083/05/01	13:00	Madhyapur Thimi	Bode WTP	Treated	Clear	1.3	<5	7.14	309	100	76	0.19	1.5	18	0.59	0	Satisfactory
7	2083/05/01	15:00	Madhyapur Thimi	Bode WTP	Treated	Clear	2.03	<5	7.1	317	100	76	0.19	1.5	18	0.4	0	Satisfactory
8	2083/05/01	13:00	Kirtipur	Ankur Metal Line	Tap	Clear	1	<5	7.42	55.5	16	220	0.1	0.02	6	0.72	0	Satisfactory
9	2083/05/01	13:05	Maharajgunj	Balaju SRT	Treated	Clear	0.3	<5	7.55	57.4	18	20	0.1	0.02	6	0.2	0	Satisfactory
10	2083/05/01	9:00	Maharajgunj	Bansbari WTP	Treated	Clear	0.06	<5	7.58	35.7	18	20	0.1	0.02	6	0.37	0	Satisfactory
11	2083/05/01	13:00	Maharajgunj	Bansbari WTP	Treated	Clear	0.17	<5	7.54	32.6	18	20	0.1	0.02	6	0.54	0	Satisfactory
12	2083/05/01	14:55	Maharajgunj	Bansbari WTP	Treated	Clear	0.13	<5	7.63	35.4	18	20	0.1	0.02	6	1.18	0	Satisfactory
13	2083/05/01	11:00	Lalitpur	Khumaltar SRT	Treated	Clear	0.4	<5	7.39	53.9	18	20	0.1	0.02	6	0.78	0	Satisfactory
14	2083/05/01	11:30	Kirtipur	Kirtipur SRT	Treated	Clear	1.1	<5	7.52	58.7	18	20	0.1	0.02	6	0.7	0	Satisfactory
15	2083/05/01	9:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.6	<5	6.67	46.5	16	18	0.1	0.02	6	1.23	0	Satisfactory
16	2083/05/01	12:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.8	<5	6.5	37.2	16	18	0.1	0.02	6	1.06	0	Satisfactory
17	2083/05/01	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.6	<5	7.38	34.8	16	20	0.1	0.02	6	1.01	0	Satisfactory
18	2083/05/01	16:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.3	<5	7.38	34.8	16	20	0.1	0.02	6	1.01	0	Satisfactory
19	2083/05/01	13:45	Maharajgunj	Panipokhari outlet	Treated	Clear	0.5	<5	7.36	47.9	16	20	0.1	0.02	6	0.2	0	Satisfactory

20	2083/05/01	12:04	Kirtipur	Tyanglaphat	Tap	Clear	0.6	<5	7.48	56.1	18	20	0.1	0.02	6	0.45	0	Satisfactory
21	2083/05/01	12:18	Kirtipur	Rudrakshe Line	Tap	Clear	0.6	<5	7.4	55.7	18	20	0.1	0.02	6	0.6	0	Satisfactory
22	2083/05/01	11:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.37	< 5	7.12	47.6	14	16	0.1	0.02	4	1.42	0	Satisfactory
23	2083/05/01	13:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.41	< 5	7.02	46.6	14	16	0.1	0.02	4	1.5	0	Satisfactory
24	2083/05/01	15:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.43	< 5	7.16	46.1	14	16	0.1	0.02	4	1.48	0	Satisfactory
25	2083/05/01	17:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.49	< 5	7.08	45.4	14	16	0.1	0.02	4	1.01	0	Satisfactory
26	2083/05/01	19:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.51	< 5	7.24	43.6	14	16	0.1	0.02	4	1.11	0	Satisfactory
27	2083/05/02	9:45	Lalitpur	Sainbu W.T.P.	Treated	Clear	3.4	<5	7.86	380	92	84	0.1	0.02	16	1.5	0	Satisfactory
28	2083/05/02	13:40	Lalitpur	Sainbu W.T.P.	Treated	Clear	3.35	<5	7.72	375	88	80	0.1	0.02	18	1	0	Satisfactory
29	2083/05/02	15:50	Lalitpur	Sainbu W.T.P.	Treated	Clear	3.28	<5	7.7	370	84	78	0.1	0.02	16	0.5	0	Satisfactory
30	2083/05/02	9:30	Madhyapur Thimi	Bode WTP	Treated	Clear	3.1	<5	6.88	306	98	74	0.38	1.5	18	0.1	0	Satisfactory
31	2083/05/02	9:00	Maharajgunj	Bansbari WTP	Treated	Clear	0.13	<5	7.46	31.6	18	20	0.1	0.02	6	0.72	0	Satisfactory
32	2083/05/02	12:55	Maharajgunj	Bansbari WTP	Treated	Clear	0.07	<5	7.53	32.4	18	20	0.1	0.02	6	0.75	0	Satisfactory
33	2083/05/02	15:25	Maharajgunj	Bansbari WTP	Treated	Clear	0.11	<5	7.64	32	18	20	0.1	0.02	6	0.94	0	Satisfactory
34	2083/05/02	9:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.7	<5	6.5	35.4	16	20	0.1	0.02	6	1.1	0	Satisfactory
35	2083/05/02	12:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1	<5	7.6	37.9	16	20	0.1	0.02	6	0.93	0	Satisfactory
36	2083/05/02	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.1	<5	6.57	50.8	18	20	0.1	0.02	6	0.78	0	Satisfactory
37	2083/05/02	16:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.8	<5	6.94	43.7	18	20	0.1	0.02	6	0.7	0	Satisfactory
38	2083/05/02	12:56	Mahankalchaur	Harijan Tole	Tap	Clear	1	<5	7.5	38.4	18	20	0.1	0.02	6	0.65	0	Satisfactory
39	2083/05/02	13:08	Mahankalchaur	Tilganga	Tap	Clear	1.8	<5	7.9	37	16	18	0.1	0.02	4	1.27	0	Satisfactory
40	2083/05/02	9:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.76	< 5	6.89	47	14	16	0.1	0.02	4	1.53	0	Satisfactory
41	2083/05/02	11:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.54	< 5	6.99	46.8	14	16	0.1	0.02	4	1.47	0	Satisfactory
42	2083/05/02	13:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.61	< 5	6.94	47.9	14	16	0.1	0.02	4	1.5	0	Satisfactory
43	2083/05/02	15:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.49	< 5	7	46	14	16	0.1	0.02	4	1.42	0	Satisfactory
44	2083/05/02	17:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.36	< 5	6.98	46.4	14	16	0.1	0.02	4	1.56	0	Satisfactory
45	2083/05/02	19:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.52	< 5	7.1	45.7	14	16	0.1	0.02	4	1.11	0	Satisfactory
46	2083/05/03	9:30	Lalitpur	Sainbu W.T.P.	Treated	Clear	3.56	<5	7.81	388	90	84	0.1	0.02	16	1	0	Satisfactory

47	2083/05/03	13:30	Lalitpur	Sainbu W.T.P.	Treated	Clear	3.5	<5	7.78	385	86	80	0.1	0.02	18	0.5	0	Satisfactory
48	2083/05/03	15:30	Lalitpur	Sainbu W.T.P.	Treated	Clear	3.4	<5	7.74	380	84	76	0.1	0.02	16	0.5	0	Satisfactory
49	2083/05/03	9:15	Madhyapur Thimi	Bode WTP	Treated	Clear	1.7	<5	6.98	306	98	76	0.38	1.5	18	0.4	0	Satisfactory
50	2083/05/03	11:25	Tripureswor	Anamnagar SRT	Treated	Clear	0.7	<5	7.83	61	18	22	0.1	0.02	6	0.28	0	Satisfactory
51	2083/05/03	9:00	Maharajgunj	Bansbari WTP	Treated	Clear	1.33	<5	7.48	36.5	18	20	0.1	0.02	6	0.83	0	Satisfactory
52	2083/05/03	12:55	Maharajgunj	Bansbari WTP	Treated	Clear	0.34	<5	7.38	36	18	20	0.1	0.02	6	0.93	0	Satisfactory
53	2083/05/03	15:45	Maharajgunj	Bansbari WTP	Treated	Clear	0.23	<5	7.43	37.1	18	20	0.1	0.02	6	0.86	0	Satisfactory
54	2083/05/03	9:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	5	<5	7.01	47.1	18	20	0.1	0.02	6	0.58	0	Satisfactory
55	2083/05/03	12:15	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.1	<5	6.85	50.1	18	20	0.1	0.02	6	0.76	0	Satisfactory
56	2083/05/03	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	3.1	<5	6.95	49.9	18	20	0.1	0.02	6	1.05	0	Satisfactory
57	2083/05/03	16:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.5	<5	7.76	51.7	18	20	0.1	0.02	6	0.61	0	Satisfactory
58	2083/05/03	11:50	Baneshwor	Minbhawan	Treated	Clear	0.5	<5	6.9	61.9	18	20	0.1	0.02	6	0.4	0	Satisfactory
59	2083/05/03	10:45	Mahankalchaur	Bhairab Temple Kalo	Tap	Clear	0.3	<5	7.64	60.1	22	20	0.1	0.02	6	0.65	0	Satisfactory
60	2083/05/03	11:14	Mahankalchaur	Kalopul	Tap	Clear	0.9	<5	7.6	59.9	18	20	0.1	0.02	6	0.83	0	Satisfactory
61	2083/05/03	11:02	Mahankalchaur	Ratopul	Tap	Clear	1	<5	7.7	60.5	18	20	0.1	0.02	6	0.76	0	Satisfactory
62	2083/05/03	13:30	Baneshwor	Devinagar Marga	Tap	Clear	2.1	<5	7.71	59.7	18	20	0.1	0.02	6	0.36	0	Satisfactory
63	2083/05/03	10:10	Mahankalchaur	New mahankal	Tap	Clear	0.1	<5	7.64	61	18	20	0.1	0.02	6	0.28	0	Satisfactory
64	2083/05/03	13:21	Mahankalchaur	Shanti Binayak Marg	Tap	Clear	1	<5	7.69	64	18	20	0.1	0.02	6	0.87	0	Satisfactory
65	2083/05/03	10:50	Mahankalchaur	Gyaneshwor	Tap	Clear	2.4	<5	7.8	66.3	18	20	0.1	0.02	6	0.35	0	Satisfactory
66	2083/05/03	13:10	Mahankalchaur	Sahabthagita Marga	Tap	Clear	0.6	<5	7.64	65	18	20	0.1	0.02	6	1.23	0	Satisfactory
67	2083/05/03	9:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.29	< 5	6.85	49.6	14	16	0.1	0.02	4	1.54	0	Satisfactory
68	2083/05/03	11:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.11	< 5	6.97	51.1	14	16	0.1	0.02	4	1.44	0	Satisfactory
69	2083/05/03	13:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.18	< 5	6.86	51.3	14	16	0.1	0.02	4	1.5	0	Satisfactory
70	2083/05/03	15:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.15	< 5	6.9	47.6	14	16	0.1	0.02	4	1.53	0	Satisfactory
71	2083/05/03	17:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.24	< 5	6.96	48.8	14	16	0.1	0.02	4	1.31	0	Satisfactory
72	2083/05/03	19:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.21	< 5	7.1	46.6	14	16	0.1	0.02	4	1.51	0	Satisfactory
73	2083/05/04	9:50	Lalitpur	Sainbu W.T.P.	Treated	Clear	2.9	<5	7.88	380	88	82	0.1	0.02	18	1.5	0	Satisfactory

74	2083/05/04	15:50	Lalitpur	Sainbu W.T.P.	Treated	Clear	2.85	<5	7.83	375	84	78	0.1	0.02	16	1	0	Satisfactory
75	2083/05/04	9:30	Madhyapur Thimi	Bode WTP	Treated	Clear	2.4	<5	6.98	307	98	76	0.38	1.5	18	0.49	0	Satisfactory
76	2083/05/04	12:30	Madhyapur Thimi	Bode WTP	Treated	Clear	2.9	<5	7.1	340	106	78	0.19	1.5	18	0.8	0	Satisfactory
77	2083/05/04	15:30	Madhyapur Thimi	Bode WTP	Treated	Clear	2.01	<5	7.1	320	104	76	0.19	1.5	18	0.37	0	Satisfactory
78	2083/05/04	8:00	Madhyapur Thimi	Tigani SRT	Treated	Clear	0.83	<5	7.5	56	20	22	0.1	0.02	6	0.12	0	Satisfactory
79	2083/05/04	13:10	Tripureshwor	Anamnagar SRT	Treated	Clear	0.1	<5	7.49	58.2	18	20	0.1	0.02	6	0.2	0	Satisfactory
80	2083/05/04	9:00	Maharajgunj	Bansbari WTP	Treated	Clear	0.17	<5	7.66	31.5	18	20	0.1	0.02	6	0.73	0	Satisfactory
81	2083/05/04	12:55	Maharajgunj	Bansbari WTP	Treated	Clear	0.13	<5	7.49	32.6	18	20	0.1	0.02	6	0.83	0	Satisfactory
82	2083/05/04	14:50	Maharajgunj	Bansbari WTP	Treated	Clear	0.23	<5	7.57	33	18	20	0.1	0.02	6	0.87	0	Satisfactory
83	2083/05/04	9:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.1	<5	6.67	45.6	18	20	0.1	0.02	6	0.6	0	Satisfactory
84	2083/05/04	12:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.5	<5	6.5	36.8	18	20	0.1	0.02	6	1.01	0	Satisfactory
85	2083/05/04	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.4	<5	6.5	40.2	18	20	0.1	0.02	6	1.14	0	Satisfactory
86	2083/05/04	16:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.1	<5	6.5	39.5	16	20	0.1	0.02	6	1.26	0	Satisfactory
87	2083/05/04	10:20	Mahankalchaur	NEW Mahankalchaur	Treated	Clear	1.4	<5	7.55	48.2	16	20	0.1	0.02	6	0.2	0	Satisfactory
88	2083/05/04	12:45	Mahankalchaur	Dillibazar	Tap	Clear	0.1	<5	7.3	55.1	18	20	0.1	0.02	6	0.92	0	Satisfactory
89	2083/05/04	12:31	Mahankalchaur	Gyaneshwor	Tap	Clear	0.2	<5	7.46	58.6	18	22	0.1	0.02	6	0.74	0	Satisfactory
90	2083/05/04	11:11	Mahankalchaur	Hira Ratna Hall(Kalodaha)	Tap	Clear	1.4	<5	7.31	39.2	16	20	0.1	0.02	4	0.51	0	Satisfactory
91	2083/05/04	12:23	Mahankalchaur	Kalopul	Tap	Clear	0.1	<5	7.35	37.4	14	16	0.1	0.02	4	0.49	0	Satisfactory
92	2083/05/04	12:18	Mahankalchaur	Maligau	Tap	Clear	1.9	<5	7.49	38.1	14	18	0.1	0.02	4	0.47	0	Satisfactory
93	2083/05/04	10:44	Mahankalchaur	Sifal Oralo	Tap	Clear	0.1	<5	7.42	38.6	16	18	0.1	0.02	4	0.65	0	Satisfactory
94	2083/05/04	11:20	Mahankalchaur	Setopul	Tap	Clear	0.1	<5	7.3	38.5	16	18	0.1	0.02	4	0.69	0	Satisfactory
95	2083/05/04	11:45	Mahankalchaur	Sanogaucharan	Tap	Clear	0.7	<5	7.38	39.3	16	18	0.1	0.02	4	0.65	0	Satisfactory
96	2083/05/04	12:57	Maharajgunj	Putalisadak	Tap	Clear	1.7	<5	7.23	93.3	24	26	0.1	0.02	10	0.67	0	Satisfactory
97	2083/05/04	11:10	Baneshwor	Ichhamati	Tap	Clear	0.1	<5	7.32	39.1	14	16	0.1	0.02	4	0.56	0	Satisfactory
98	2083/05/04	10:51	Mahankalchaur	Global Institute, Sifal	Tap	Clear	0.1	<5	7.3	39.9	22	24	0.1	0.02	8	0.66	0	Satisfactory
99	2083/05/04	9:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	1.73	< 5	7.25	40.7	14	16	0.1	0.02	4	1.5	0	Satisfactory
100	2083/05/04	11:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	1.63	< 5	7.18	40.5	14	16	0.1	0.02	4	1.41	0	Satisfactory

101	2083/05/04	13:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	1.78	< 5	6.93	41.4	14	16	0.1	0.02	4	1.53	0	Satisfactory
102	2083/05/04	15:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	1.68	< 5	6.86	42.9	14	16	0.1	0.02	4	1.54	0	Satisfactory
103	2083/05/04	17:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.82	< 5	6.91	42.7	14	16	0.1	0.02	4	1.5	0	Satisfactory
104	2083/05/04	19:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.89	< 5	6.98	44.6	14	16	0.1	0.02	4	1.11	0	Satisfactory
105	2083/05/05	9:55	Lalitpur	Sainbu W.T.P.	Treated	Clear	5	<5	7.89	402	100	92	0.1	0.02	18	1.5	0	Satisfactory
106	2083/05/05	13:20	Lalitpur	Sainbu W.T.P.	Treated	Clear	5	<5	7.82	399	96	90	0.1	0.02	16	1.3	0	Satisfactory
107	2083/05/05	15:55	Lalitpur	Sainbu W.T.P.	Treated	Clear	5	<5	7.8	395	92	84	0.1	0.02	16	1	0	Satisfactory
108	2083/05/05	9:30	Madhyapur Thimi	Bode WTP	Treated	Clear	1.76	<5	6.97	288	96	76	0.38	1.5	18	0.28	0	Satisfactory
109	2083/05/05	12:30	Madhyapur Thimi	Bode WTP	Treated	Clear	2.04	<5	7.01	300	100	76	0.38	1.5	18	0.48	0	Satisfactory
110	2083/05/05	8:45	Madhyapur Thimi	Tigani SRT	Treated	Clear	0.78	<5	7.5	70	22	26	0.1	0.02	8	0.1	0	Satisfactory
111	2083/05/05	9:10	Maharajgunj	Bansbari WTP	Treated	Clear	0.35	<5	7.53	34.2	18	20	0.1	0.02	6	0.76	0	Satisfactory
112	2083/05/05	13:35	Maharajgunj	Bansbari WTP	Treated	Clear	0.18	<5	7.56	33	18	20	0.1	0.02	6	0.91	0	Satisfactory
113	2083/05/05	15:55	Maharajgunj	Bansbari WTP	Treated	Clear	0.15	<5	7.61	32.5	18	20	0.1	0.02	6	1.04	0	Satisfactory
114	2083/05/05	12:50	Lalitpur	Khumaltar SRT	Treated	Clear	0.6	<5	7.2	49.3	18	18	0.1	0.02	6	0.78	0	Satisfactory
115	2083/05/05	11:30	Kirtipur	Kirtipur SRT	Treated	Clear	0.3	<5	7.3	58.6	18	20	0.1	0.02	6	0.57	0	Satisfactory
116	2083/05/05	9:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.5	<5	6.5	46.9	18	20	0.1	0.02	4	1.24	0	Satisfactory
117	2083/05/05	12:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.2	<5	6.5	59.6	18	20	0.1	0.02	6	1.9	0	Satisfactory
118	2083/05/05	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.4	<5	6.63	52.8	18	20	0.1	0.02	6	1.15	0	Satisfactory
119	2083/05/05	16:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.2	<5	6.8	46.8	18	20	0.1	0.02	4	0.88	0	Satisfactory
120	2083/05/05	10:20	Maharajgunj	Panipokhari outlet	Treated	Clear	0.1	<5	7.2	43.1	16	20	0.1	0.02	6	0.2	0	Satisfactory
121	2083/05/05	14:35	Maharajgunj	Baggikhana	Tap	Clear	0.6	<5	7.68	56.5	18	20	0.1	0.02	6	0.66	0	Satisfactory
122	2083/05/05	13:31	Mahankalchaur	Tilganga	Tap	Clear	0.3	<5	7.23	46.2	16	18	0.1	0.02	6	0.77	0	Satisfactory
123	2083/05/05	15:12	Maharajgunj	Kamaladi	Tap	Clear	0.3	<5	7.42	53.6	18	20	0.1	0.02	6	0.44	0	Satisfactory
124	2083/05/05	11:45	Kirtipur	Behind TU	Tap	Clear	0.1	<5	7.04	57.5	18	20	0.1	0.02	6	0.67	0	Satisfactory
125	2083/05/05	13:21	Mahankalchaur	Harijan Tole(Tilganga)	Tap	Clear	0.4	<5	6.5	46	16	18	0.1	0.02	4	0.94	0	Satisfactory
126	2083/05/05	14:50	Maharajgunj	Putalisadak	Tap	Clear	0.4	<5	7.6	54.1	18	20	0.1	0.02	6	0.72	0	Satisfactory
127	2083/05/05	11:40	Kirtipur	Sundarbasti Tyagla	Tap	Clear	0.1	<5	7.58	58.7	18	20	0.1	0.02	6	0.66	0	Satisfactory

128	2083/05/05	9:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.23	< 5	6.5	44.9	14	16	0.1	0.02	4	1.5	0	Satisfactory
129	2083/05/05	11:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.37	< 5	6.96	41.7	14	16	0.1	0.02	4	1.22	0	Satisfactory
130	2083/05/05	13:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.55	< 5	6.97	42.5	14	16	0.1	0.02	4	1.4	0	Satisfactory
131	2083/05/05	15:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.41	< 5	6.98	42.9	14	16	0.1	0.02	4	1.27	0	Satisfactory
132	2083/05/05	17:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.35	< 5	6.89	42.7	14	16	0.1	0.02	4	1.43	0	Satisfactory
133	2083/05/05	19:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.4	< 5	7.01	43.9	14	16	0.1	0.02	4	1.51	0	Satisfactory
134	2083/05/06	10:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.95	< 5	7.01	43.8	14	16	0.1	0.02	4	1.56	0	Satisfactory
135	2083/05/06	13:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.72	< 5	6.99	44.7	14	16	0.1	0.02	4	1.42	0	Satisfactory
136	2083/05/06	16:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.67	< 5	7.26	42.3	14	16	0.1	0.02	4	1	0	Satisfactory
137	2083/05/07	9:00	Maharajgunj	Bansbari WTP	Treated	Clear	0.29	<5	7.48	34.2	18	20	0.1	0.02	6	0.77	0	Satisfactory
138	2083/05/07	12:55	Maharajgunj	Bansbari WTP	Treated	Clear	0.18	<5	7.51	31.7	18	20	0.1	0.02	6	0.54	0	Satisfactory
139	2083/05/07	10:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.37	< 5	6.93	46.7	14	16	0.1	0.02	4	1.24	0	Satisfactory
140	2083/05/07	13:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.37	< 5	7.31	42.2	14	16	0.1	0.02	4	1.12	0	Satisfactory
141	2083/05/07	15:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.57	< 5	7.04	43.6	14	16	0.1	0.02	4	1.52	0	Satisfactory
142	2083/05/07	17:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.64	< 5	7.29	40.9	14	16	0.1	0.02	4	1.02	0	Satisfactory
143	2083/05/08	9:40	Lalitpur	Sainbu W.T.P.	Treated	Clear	5	<5	7.92	396	98	90	0.1	0.02	16	1.9	0	Satisfactory
144	2083/05/08	13:45	Lalitpur	Sainbu W.T.P.	Treated	Clear	5	<5	7.86	392	94	86	0.1	0.02	18	1.5	0	Satisfactory
145	2083/05/08	15:50	Lalitpur	Sainbu W.T.P.	Treated	Clear	5	<5	7.82	388	90	80	0.1	0.02	18	1	0	Satisfactory
146	2083/05/08	9:30	Madhyapur Thimi	Bode WTP	Treated	Clear	2.63	<5	7.29	310	102	78	0.38	1.5	20	0.96	0	Satisfactory
147	2083/05/08	13:00	Madhyapur Thimi	Bode WTP	Treated	Clear	2.96	<5	7.34	356	108	80	0.19	1.5	20	1.17	0	Satisfactory
148	2083/05/08	15:00	Madhyapur Thimi	Bode WTP	Treated	Clear	2.77	<5	7.28	330	104	78	0.19	1.5	20	1.04	0	Satisfactory
149	2083/05/08	12:13	Tripureshwor	Anamnagar SRT	Treated	Clear	0.6	<5	7.18	55	18	20	0.1	0.02	6	0.9	0	Satisfactory
150	2083/05/08	9:00	Maharajgunj	Bansbari WTP	Treated	Clear	0.75	<5	7.45	33.7	18	20	0.1	0.02	6	0.92	0	Satisfactory
151	2083/05/08	13:25	Maharajgunj	Bansbari WTP	Treated	Clear	0.23	<5	7.55	29.24	18	20	0.1	0.02	6	0.68	0	Satisfactory
152	2083/05/08	13:15	Lalitpur	Khumaltar SRT	Treated	Clear	0.3	<5	7.27	50.8	18	20	0.1	0.02	6	0.79	0	Satisfactory
153	2083/05/08	9:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.3	<5	6.5	40.2	18	20	0.1	0.02	4	0.56	0	Satisfactory
154	2083/05/08	12:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.4	<5	6.61	47.2	18	20	0.1	0.02	4	1.9	0	Satisfactory

155	2083/05/08	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.5	<5	6.59	42.5	18	20	0.1	0.02	4	1.04	0	Satisfactory
156	2083/05/08	16:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.6	<5	6.64	40.9	18	20	0.1	0.02	4	1.35	0	Satisfactory
157	2083/05/08	15:10	Baneshwor	Minbhawan SRT	Treated	Clear	0.4	<5	7.02	48.9	16	20	0.1	0.02	6	0.25	0	Satisfactory
158	2083/05/08	11:10	Mahankalchaur	NEW Mahankalchaur	Treated	Clear	1.9	<5	7.4	48.4	16	20	0.1	0.02	6	0.2	0	Satisfactory
159	2083/05/08	11:55	Mahankalchaur	Kalopul	Tap	Clear	0.3	<5	7.15	39	14	16	0.1	0.02	4	0.36	0	Satisfactory
160	2083/05/08	14:05	Baneshwor	Sahayogi Marga	Tap	Clear	0.6	<5	7.31	51.5	18	20	0.1	0.02	6	0.81	0	Satisfactory
161	2083/05/08	14:00	Baneshwor	Samudayik Marga	Tap	Clear	0.6	<5	7.46	54.1	18	20	0.1	0.02	6	0.2	0	Satisfactory
162	2083/05/08	15:35	Baneshwor	Devinagar Marga	Tap	Clear	0.7	<5	7.47	54.5	18	20	0.1	0.02	6	0.33	0	Satisfactory
163	2083/05/08	15:25	Baneshwor	Thapagau	Tap	Clear	5	<5	7.34	51.5	18	20	0.1	0.02	6	0.3	0	Satisfactory
164	2083/05/08	11:45	Mahankalchaur	Siphalchaur	Tap	Clear	0.3	<5	7.29	39.5	18	20	0.1	0.02	4	0.27	0	Satisfactory
165	2083/05/08	12:00	Mahankalchaur	Sanogaucharan	Tap	Clear	1.9	<5	7.41	39.5	14	16	0.1	0.02	4	0.33	0	Satisfactory
166	2083/05/08	13:50	Baneshwor	Bhismagalli Marga	Tap	Clear	0.6	<5	7.22	54.4	16	20	0.1	0.02	6	0.86	0	Satisfactory
167	2083/05/08	9:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.44	< 5	6.9	44.2	14	16	0.1	0.02	4	1.53	0	Satisfactory
168	2083/05/08	11:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.41	< 5	6.95	44.4	14	16	0.1	0.02	4	1.5	0	Satisfactory
169	2083/05/08	13:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.51	< 5	6.91	44.8	14	16	0.1	0.02	4	1.42	0	Satisfactory
170	2083/05/08	15:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.33	< 5	6.96	44.2	14	16	0.1	0.02	4	1.12	0	Satisfactory
171	2083/05/08	17:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.35	< 5	7.01	44.9	14	16	0.1	0.02	4	1.06	0	Satisfactory
172	2083/05/08	19:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.41	< 5	6.98	43.2	14	16	0.1	0.02	4	1.17	0	Satisfactory
173	2083/05/09	10:00	Lalitpur	Sainbu W.T.P.	Treated	Clear	5	<5	7.87	395	96	88	0.1	0.02	18	1.5	0	Satisfactory
174	2083/05/09	13:25	Lalitpur	Sainbu W.T.P.	Treated	Clear	5	<5	7.85	390	90	80	0.1	0.02	16	1	0	Satisfactory
175	2083/05/09	15:55	Lalitpur	Sainbu W.T.P.	Treated	Clear	5	<5	7.8	386	86	76	0.1	0.02	18	0.5	0	Satisfactory
176	2083/05/09	9:30	Madhyapur Thimi	Bode WTP	Treated	Clear	2.5	<5	7.26	297	100	76	0.19	1.5	20	0.59	0	Satisfactory
177	2083/05/09	12:30	Madhyapur Thimi	Bode WTP	Treated	Clear	2.4	<5	7.25	309	102	76	0.19	1.5	20	0.94	0	Satisfactory
178	2083/05/09	10:13	Tripureshwor	Anamnagar SRT	Treated	Clear	0.3	<5	7.62	55.7	18	20	0.1	0.02	6	0.76	0	Satisfactory
179	2083/05/09	9:00	Maharajgunj	Bansbari WTP	Treated	Clear	1.07	<5	7.52	35.4	18	20	0.1	0.02	6	0.66	0	Satisfactory
180	2083/05/09	13:35	Maharajgunj	Bansbari WTP	Treated	Clear	1.13	<5	7.34	32.3	18	20	0.1	0.02	6	0.76	0	Satisfactory
181	2083/05/09	15:10	Maharajgunj	Bansbari WTP	Treated	Clear	0.35	<5	7.44	33.2	18	20	0.1	0.02	6	0.62	0	Satisfactory

182	2083/05/09	9:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	5	<5	7.85	71	20	20	0.1	0.02	8	1.9	0	Satisfactory
183	2083/05/09	12:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	3.5	<5	6.9	50.6	18	20	0.1	0.02	6	1.76	0	Satisfactory
184	2083/05/09	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.8	<5	7.11	58.8	18	20	0.1	0.02	6	0.82	0	Satisfactory
185	2083/05/09	16:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.7	<5	6.52	35.7	14	20	0.1	0.02	4	0.2	0	Satisfactory
186	2083/05/09	15:00	Mahankalchaur	NEW Mahankalchaur	Treated	Clear	0.8	<5	7.1	53.6	18	20	0.1	0.02	6	0.95	0	Satisfactory
187	2083/05/09	15:05	Mahankalchaur	Kapan Balkumari Tol	Tap	Clear	2.9	<5	7.55	57.3	18	20	0.1	0.02	6	0.71	0	Satisfactory
188	2083/05/09	15:35	Mahankalchaur	Falfulbazar (Kapan)	Tap	Clear	2.1	<5	6.57	56.2	18	20	0.1	0.02	6	0.71	0	Satisfactory
189	2083/05/09	11:00	Baneshwor	Bijulibazar	Tap	Clear	0.2	<5	7.4	54	18	20	0.1	0.02	6	0.2	0	Satisfactory
190	2083/05/09	15:20	Mahankalchaur	Tarkaribazar (Kapan)	Tap	Clear	3	<5	6.6	54.1	18	20	0.1	0.02	6	0.87	0	Satisfactory
191	2083/05/09	9:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.31	< 5	6.97	45.1	14	16	0.1	0.02	4	1.43	0	Satisfactory
192	2083/05/09	11:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.34	< 5	6.99	45.3	14	16	0.1	0.02	4	1.37	0	Satisfactory
193	2083/05/09	13:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.12	< 5	7.22	46.4	14	16	0.1	0.02	4	1.16	0	Satisfactory
194	2083/05/09	15:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.28	< 5	6.86	46.6	14	16	0.1	0.02	4	1.51	0	Satisfactory
195	2083/05/09	17:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.56	< 5	6.94	44.8	14	16	0.1	0.02	4	1.43	0	Satisfactory
196	2083/05/09	19:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.38	< 5	7.1	46.6	14	16	0.1	0.02	4	1.31	0	Satisfactory
197	2083/05/10	9:35	Lalitpur	Sainbu W.T.P.	Treated	Clear	3.85	<5	7.86	390	94	86	0.1	0.02	18	1.9	0	Satisfactory
198	2083/05/10	13:40	Lalitpur	Sainbu W.T.P.	Treated	Clear	3.8	<5	7.82	386	90	80	0.1	0.02	18	1.5	0	Satisfactory
199	2083/05/10	15:32	Lalitpur	Sainbu W.T.P.	Treated	Clear	3.75	<5	7.78	382	86	78	0.1	0.02	16	1	0	Satisfactory
200	2083/05/10	9:30	Madhyapur Thimi	Bode WTP	Treated	Clear	3.31	<5	7.26	291.7	100	74	0.38	1.5	20	0.2	0	Satisfactory
201	2083/05/10	12:30	Madhyapur Thimi	Bode WTP	Treated	Clear	1.96	<5	7.2	317	102	76	0.19	1.5	20	0.66	0	Satisfactory
202	2083/05/10	15:00	Madhyapur Thimi	Bode WTP	Treated	Clear	1.86	<5	7.18	303	102	76	0.38	1.5	20	0.39	0	Satisfactory
203	2083/05/10	12:24	Tripureshwor	Anamnagar SRT	Treated	Clear	0.3	<5	7.56	60.1	18	22	0.1	0.02	6	0.32	0	Satisfactory
204	2083/05/10	9:25	Maharajgunj	Bansbari WTP	Treated	Clear	3.15	<5	7.26	34.2	18	20	0.1	0.02	6	0.45	0	Satisfactory
205	2083/05/10	12:50	Maharajgunj	Bansbari WTP	Treated	Clear	0.65	<5	7.23	32.4	18	20	0.1	0.02	6	0.54	0	Satisfactory
206	2083/05/10	14:55	Maharajgunj	Bansbari WTP	Treated	Clear	0.32	<5	7.34	31.6	18	20	0.1	0.02	6	0.91	0	Satisfactory
207	2083/05/10	13:25	Lalitpur	Khumaltar SRT	Treated	Clear	0.5	<5	7.43	54.2	18	20	0.1	0.02	6	0.82	0	Satisfactory
208	2083/05/10	9:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.9	<5	6.59	41.2	16	20	0.1	0.02	4	0.95	0	Satisfactory

209	2083/05/10	12:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.7	<5	6.5	64.5	18	20	0.1	0.02	6	1.9	0	Satisfactory
210	2083/05/10	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1	<5	6.67	59.5	18	20	0.1	0.02	6	0.67	0	Satisfactory
211	2083/05/10	16:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.5	<5	6.71	48.3	18	20	0.1	0.02	6	0.95	0	Satisfactory
212	2083/05/10	12:40	Baneshwor	Minbhawan SRT	Treated	Clear	0.8	<5	7.48	50.3	18	20	0.1	0.02	6	0.5	0	Satisfactory
213	2083/05/10	10:45	Mahankalchaur	NEW Mahankalchaur	Treated	Clear	2.9	<5	7.37	51.8	18	20	0.1	0.02	6	0.2	0	Satisfactory
214	2083/05/10	11:41	Mahankalchaur	Setopul(New Mahank	Tap	Clear	1	<5	7.27	54.1	18	20	0.1	0.02	6	0.33	0	Satisfactory
215	2083/05/10	11:18	Mahankalchaur	Gyaneshwor	Tap	Clear	0.9	<5	7.15	54	18	20	0.1	0.02	6	0.27	0	Satisfactory
216	2083/05/10	12:07	Maharajgunj	Dillibazar	Tap	Clear	0.8	<5	7.38	54.4	18	20	0.1	0.02	6	0.27	0	Satisfactory
217	2083/05/10	13:35	Lalitpur	Ganga Jamuna (Khu	Tap	Clear	0.6	<5	7.26	47.8	18	20	0.1	0.02	6	0.73	0	Satisfactory
218	2083/05/10	11:55	Mahankalchaur	Ratopul (New Mahan	Tap	Clear	1	<5	8.5	63.1	18	20	0.1	0.02	6	0.2	0	Satisfactory
219	2083/05/10	15:10	Mahankalchaur	Bhatkekopul,Sinama	Tap	Clear	0.4	<5	7.08	43.4	16	18	0.1	0.02	4	0.62	0	Satisfactory
220	2083/05/10	12:12	Mahankalchaur	Dillibazar Kalikastha	Tap	Clear	0.8	<5	7.4	54.6	18	20	0.1	0.02	6	0.32	0	Satisfactory
221	2083/05/10	11:32	Mahankalchaur	Maitidevi(New Mahar	Tap	Clear	0.8	<5	7.47	54.4	18	20	0.1	0.02	6	0.31	0	Satisfactory
222	2083/05/10	9:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.22	< 5	6.87	42.9	14	16	0.1	0.02	4	1.5	0	Satisfactory
223	2083/05/10	11:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.18	< 5	6.84	43.2	14	16	0.1	0.02	4	1.54	0	Satisfactory
224	2083/05/10	13:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.5	< 5	7.07	42	14	16	0.1	0.02	4	1.48	0	Satisfactory
225	2083/05/10	15:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.49	< 5	7.03	41.1	14	16	0.1	0.02	4	1.46	0	Satisfactory
226	2083/05/10	17:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.61	< 5	6.88	42.6	14	16	0.1	0.02	4	1.38	0	Satisfactory
227	2083/05/11	9:45	Lalitpur	Sainbu W.T.P.	Treated	Clear	3.7	<5	7.86	394	96	88	0.1	0.02	18	1.5	0	Satisfactory
228	2083/05/11	13:40	Lalitpur	Sainbu W.T.P.	Treated	Clear	3.68	<5	7.83	390	92	84	0.1	0.02	16	1	0	Satisfactory
229	2083/05/11	15:45	Lalitpur	Sainbu W.T.P.	Treated	Clear	3.62	<5	7.8	386	88	80	0.1	0.02	18	0.5	0	Satisfactory
230	2083/05/11	9:30	Madhyapur Thimi	Bode WTP	Treated	Clear	1.47	<5	7.2	312	102	78	0.38	1.5	20	0.65	0	Satisfactory
231	2083/05/11	12:30	Madhyapur Thimi	Bode WTP	Treated	Clear	2.7	<5	7.25	334	106	80	0.38	1.5	20	1.16	0	Satisfactory
232	2083/05/11	15:00	Madhyapur Thimi	Bode WTP	Treated	Clear	3.01	<5	7.2	320	102	76	0.38	1.5	20	0.96	0	Satisfactory
233	2083/05/11	8:55	Maharajgunj	Bansbari WTP	Treated	Clear	0.75	<5	7.07	34.3	18	20	0.1	0.02	6	0.75	0	Satisfactory
234	2083/05/11	13:15	Maharajgunj	Bansbari WTP	Treated	Clear	0.37	<5	7.17	32.2	18	20	0.1	0.02	6	0.85	0	Satisfactory
235	2083/05/11	15:45	Maharajgunj	Bansbari WTP	Treated	Clear	0.24	<5	7.31	26.61	18	20	0.1	0.02	6	0.94	0	Satisfactory

236	2083/05/11	12:30	Lalitpur	Khumaltar SRT	Treated	Clear	0.4	<5	6.56	75.1	20	22	0.1	0.02	8	1.41	0	Satisfactory
237	2083/05/11	11:22	Kirtipur	Kirtipur SRT	Treated	Clear	0.3	<5	7.27	83.1	22	24	0.1	0.02	8	0.37	0	Satisfactory
238	2083/05/11	9:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.5	<5	7.48	51.8	18	20	0.1	0.02	6	0.73	0	Satisfactory
239	2083/05/11	12:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.1	<5	6.76	49.7	18	20	0.1	0.02	6	1.01	0	Satisfactory
240	2083/05/11	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.1	<5	7.01	51.2	18	20	0.1	0.02	6	1.04	0	Satisfactory
241	2083/05/11	16:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.2	<5	6.7	63.6	18	20	0.1	0.02	6	0.98	0	Satisfactory
242	2083/05/11	15:02	Maharajgunj	Panipokhari outlet	Treated	Clear	1.5	<5	6.5	54.3	18	20	0.1	0.02	6	0.2	0	Satisfactory
243	2083/05/11	11:25	Kirtipur	Behind TU	Tap	Clear	0.3	<5	7.16	79.2	18	20	0.1	0.02	6	0.49	0	Satisfactory
244	2083/05/11	12:48	Lalitpur	Khumaltar Kantimarg	Tap	Clear	0.8	<5	7.5	79.2	18	20	0.1	0.02	6	0.88	0	Satisfactory
245	2083/05/11	11:46	Kirtipur	Shivalaya (Kirtipur)	Tap	Clear	0.4	<5	7.05	83.4	22	24	0.1	0.02	8	0.37	0	Satisfactory
246	2083/05/11	13:58	Maharajgunj	Putalisadak (Panipok)	Tap	Clear	0.6	<5	6.99	74.8	22	24	0.1	0.02	8	0.46	0	Satisfactory
247	2083/05/11	13:43	Maharajgunj	Baggikhana	Tap	Clear	1.1	<5	7.26	83.8	20	24	0.1	0.02	8	0.2	0	Satisfactory
248	2083/05/11	14:10	Maharajgunj	Bagbazar	Tap	Clear	0.8	<5	7.08	82.3	20	24	0.1	0.02	8	0.33	0	Satisfactory
249	2083/05/11	12:45	Lalitpur	Melamchi marga puri	Tap	Clear	0.2	<5	6.5	76.4	22	24	0.1	0.02	6	1.15	0	Satisfactory
250	2083/05/11	14:25	Maharajgunj	Kamaladi	Tap	Clear	0.8	<5	7.13	77.7	22	24	0.1	0.02	8	0.21	0	Satisfactory
251	2083/05/11	9:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.32	< 5	6.89	42.5	14	16	0.1	0.02	4	1.17	0	Satisfactory
252	2083/05/11	11:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.39	< 5	7.13	40.1	14	16	0.1	0.02	4	0.5	0	Satisfactory
253	2083/05/11	13:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.67	< 5	7.02	41.9	14	16	0.1	0.02	4	0.98	0	Satisfactory
254	2083/05/11	15:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.51	< 5	6.92	44.6	14	16	0.1	0.02	4	1.23	0	Satisfactory
255	2083/05/11	17:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.32	< 5	6.96	43.6	14	16	0.1	0.02	4	1.5	0	Satisfactory
256	2083/05/12	7:25	Maharajgunj	Bansbari WTP	Treated	Clear	0.28	<5	7.57	38.2	18	20	0.1	0.02	6	1.18	0	Satisfactory
257	2083/05/12	13:15	Maharajgunj	Bansbari WTP	Treated	Clear	0.15	<5	7.45	37.6	18	20	0.1	0.02	6	1.13	0	Satisfactory
258	2083/05/12	15:35	Maharajgunj	Bansbari WTP	Treated	Clear	0.09	<5	7.37	27.44	18	20	0.1	0.02	6	0.73	0	Satisfactory
259	2083/05/12	12:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.48	< 5	6.82	43.7	14	16	0.1	0.02	4	1.5	0	Satisfactory
260	2083/05/12	14:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.85	< 5	6.93	39.8	14	16	0.1	0.02	4	1.56	0	Satisfactory
261	2083/05/13	8:45	Maharajgunj	Bansbari WTP	Treated	Clear	0.24	<5	7.21	26.96	18	20	0.1	0.02	6	0.51	0	Satisfactory
262	2083/05/13	13:00	Maharajgunj	Bansbari WTP	Treated	Clear	0.17	<5	7.43	31.5	18	20	0.1	0.02	6	1.23	0	Satisfactory

263	2083/05/13	15:45	Maharajgunj	Bansbari WTP	Treated	Clear	0.13	<5	7.52	31	18	20	0.1	0.02	6	1.05	0	Satisfactory
264	2083/05/13	10:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.49	< 5	6.79	44.2	14	16	0.1	0.02	4	1.5	0	Satisfactory
265	2083/05/13	12:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.25	< 5	6.89	43.3	14	16	0.1	0.02	4	1.42	0	Satisfactory
266	2083/05/13	14:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.51	< 5	6.91	43.5	14	16	0.1	0.02	4	1.46	0	Satisfactory
267	2083/05/13	17:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.62	< 5	7	43.3	14	16	0.1	0.02	4	1.35	0	Satisfactory
268	2083/05/14	8:50	Maharajgunj	Bansbari WTP	Treated	Clear	0.19	<5	7.57	30.2	18	20	0.1	0.02	6	0.92	0	Satisfactory
269	2083/05/14	12:45	Maharajgunj	Bansbari WTP	Treated	Clear	0.16	<5	7.48	29.92	18	20	0.1	0.02	6	0.72	0	Satisfactory
270	2083/05/14	15:55	Maharajgunj	Bansbari WTP	Treated	Clear	0.13	<5	7.45	27.36	18	20	0.1	0.02	6	0.62	0	Satisfactory
271	2083/05/14	10:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.63	< 5	6.66	48.6	14	16	0.1	0.02	4	1.55	0	Satisfactory
272	2083/05/14	12:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.75	< 5	6.6	47.4	14	16	0.1	0.02	4	1.5	0	Satisfactory
273	2083/05/14	14:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.87	< 5	6.77	41.8	14	16	0.1	0.02	4	1.19	0	Satisfactory
274	2083/05/14	17:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	1.31	< 5	6.85	41.4	14	16	0.1	0.02	4	0.94	0	Satisfactory
275	2083/05/15	9:40	Lalitpur	Sainbu W.T.P.	Treated	Clear	3.05	<5	7.89	395	96	88	0.1	0.02	18	1.5	0	Satisfactory
276	2083/05/15	13:45	Lalitpur	Sainbu W.T.P.	Treated	Clear	3.02	<5	7.85	390	92	84	0.1	0.02	16	1	0	Satisfactory
277	2083/05/15	15:55	Lalitpur	Sainbu W.T.P.	Treated	Clear	3	<5	7.8	388	88	80	0.1	0.02	18	0.5	0	Satisfactory
278	2083/05/15	9:30	Madhyapur Thimi	Bode WTP	Treated	Clear	1.87	<5	7.15	333	104	78	0.19	1.5	20	1.05	0	Satisfactory
279	2083/05/15	13:00	Madhyapur Thimi	Bode WTP	Treated	Clear	2.47	<5	6.93	344	104	76	0.38	1.5	20	0.23	0	Satisfactory
280	2083/05/15	15:00	Madhyapur Thimi	Bode WTP	Treated	Clear	2.6	<5	6.9	339	104	76	0.38	1.5	20	0.21	0	Satisfactory
281	2083/05/15	9:00	Madhyapur Thimi	Tigani SRT	Treated	Clear	0.75	<5	7.53	45.2	16	18	0.1	0.02	4	0.2	0	Satisfactory
282	2083/05/15	13:05	Tripureshwor	Anamnagar SRT	Treated	Clear	0.6	<5	7.36	64	18	22	0.1	0.02	6	0.2	0	Satisfactory
283	2083/05/15	9:00	Maharajgunj	Bansbari WTP	Treated	Clear	2.7	<5	7.47	33.7	18	20	0.1	0.02	6	1.15	0	Satisfactory
284	2083/05/15	12:55	Maharajgunj	Bansbari WTP	Treated	Clear	0.17	<5	7.41	30.2	18	20	0.1	0.02	6	0.84	0	Satisfactory
285	2083/05/15	15:50	Maharajgunj	Bansbari WTP	Treated	Clear	0.13	<5	7.51	28.02	18	20	0.1	0.02	6	0.67	0	Satisfactory
286	2083/05/15	14:25	Lalitpur	Khumaltar SRT	Treated	Clear	0.4	<5	7.22	58	18	20	0.1	0.02	6	1.11	0	Satisfactory
287	2083/05/15	9:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.4	<5	7.02	52.4	18	20	0.1	0.02	6	0.81	0	Satisfactory
288	2083/05/15	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.9	<5	6.97	43.4	18	20	0.1	0.02	4	1.31	0	Satisfactory
289	2083/05/15	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.2	<5	6.52	43.7	18	20	0.1	0.02	4	1.45	0	Satisfactory

290	2083/05/15	16:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.3	<5	6.5	44.3	16	18	0.1	0.02	4	1.39	0	Satisfactory
291	2083/05/15	13:20	Baneshwor	Minbhawan SRT	Treated	Clear	0.1	<5	7.22	56.2	18	20	0.1	0.02	6	0.2	0	Satisfactory
292	2083/05/15	10:30	Mahankalchaur	NEW Mahankalchaur	Treated	Clear	2.7	<5	7.23	56.5	18	20	0.1	0.02	6	0.2	0	Satisfactory
293	2083/05/15	14:55	Lalitpur	Shantinagar Margak	Tap	Clear	0.5	<5	7.66	93.7	24	28	0.1	0.02	10	0.2	0	Satisfactory
294	2083/05/15	14:43	Lalitpur	Krishigairi dhara Mar	Tap	Clear	0.5	<5	7.09	68	18	20	0.1	0.02	6	1.19	0	Satisfactory
295	2083/05/15	11:00	Mahankalchaur	Sifalchaur(New Maha	Tap	Clear	0.3	<5	6.5	43	16	18	0.1	0.02	6	0.84	0	Satisfactory
296	2083/05/15	11:25	Mahankalchaur	Kalopul	Tap	Clear	0.2	<5	7.1	46	16	18	0.1	0.02	6	0.72	0	Satisfactory
297	2083/05/15	11:28	Mahankalchaur	Sanogaucharan(New	Tap	Clear	1.5	<5	6.51	44	16	18	0.1	0.02	6	0.68	0	Satisfactory
298	2083/05/15	12:18	Mahankalchaur	Maligau (New Mahan	Tap	Clear	0.1	<5	7	43.1	16	18	0.1	0.02	6	0.76	0	Satisfactory
299	2083/05/15	12:06	Mahankalchaur	Ratopul (New Mahan	Tap	Clear	0.3	<5	6.5	57.5	18	20	0.1	0.02	6	0.5	0	Satisfactory
300	2083/05/15	12:25	Mahankalchaur	Hadigao (Mahankalch	Tap	Clear	0.3	<5	6.5	45.6	18	20	0.1	0.02	6	1.03	0	Satisfactory
301	2083/05/15	12:49	Mahankalchaur	Gahanapokhari ,Han	Tap	Clear	0.6	<5	7.05	59.9	18	20	0.1	0.02	6	0.64	0	Satisfactory
302	2083/05/15	11:39	Maharajgunj	Big Mart Naxal	Tap	Clear	0.5	<5	7.12	57.9	16	20	0.1	0.02	6	0.67	0	Satisfactory
303	2083/05/15	11:18	Mahankalchaur	Sifal Barale (New Ma	Tap	Clear	0.4	<5	6.7	32.9	12	14	0.1	0.02	4	0.81	0	Satisfactory
304	2083/05/15	12:34	Mahankalchaur	Bhatbhateni Tangal	Tap	Clear	0.8	<5	7	47	18	20	0.1	0.02	6	0.63	0	Satisfactory
305	2083/05/15	9:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.57	< 5	6.76	45.2	14	16	0.1	0.02	4	1.32	0	Satisfactory
306	2083/05/15	11:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.45	< 5	6.81	43.1	14	16	0.1	0.02	4	1.46	0	Satisfactory
307	2083/05/15	13:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.47	< 5	6.98	42.7	14	16	0.1	0.02	4	1.04	0	Satisfactory
308	2083/05/15	15:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.49	< 5	6.77	43.5	14	16	0.1	0.02	4	1.52	0	Satisfactory
309	2083/05/15	17:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.31	< 5	6.84	44	14	16	0.1	0.02	4	1.13	0	Satisfactory
310	2083/05/15	19:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.51	< 5	6.94	44.1	14	16	0.1	0.02	4	1.51	0	Satisfactory
311	2083/05/16	9:45	Lalitpur	Sainbu W.T.P.	Treated	Clear	3.7	<5	7.87	390	94	86	0.1	0.02	18	1	0	Satisfactory
312	2083/05/16	13:42	Lalitpur	Sainbu W.T.P.	Treated	Clear	3.63	<5	7.82	387	90	80	0.1	0.02	16	1	0	Satisfactory
313	2083/05/16	15:50	Lalitpur	Sainbu W.T.P.	Treated	Clear	3.62	<5	7.79	383	86	78	0.1	0.02	18	0.5	0	Satisfactory
314	2083/05/16	9:30	Madhyapur Thimi	Bode WTP	Treated	Clear	2.97	<5	7.01	281.1	98	70	0.38	1.5	20	0.2	0	Satisfactory
315	2083/05/16	13:00	Madhyapur Thimi	Bode WTP	Treated	Clear	2.8	<5	6.94	317	102	76	0.38	1.5	20	0.14	0	Satisfactory
316	2083/05/16	15:00	Madhyapur Thimi	Bode WTP	Treated	Clear	2.41	<5	6.92	313	100	76	0.38	1.5	20	0.22	0	Satisfactory

317	2083/05/16	13:28	Tripureshwor	Anamnagar SRT	Treated	Clear	1	<5	7.35	66	20	22	0.1	0.02	8	0.2	0	Satisfactory
318	2083/05/16	9:00	Maharajgunj	Bansbari WTP	Treated	Clear	0.23	<5	7.53	33.3	18	20	0.1	0.02	6	1.35	0	Satisfactory
319	2083/05/16	12:55	Maharajgunj	Bansbari WTP	Treated	Clear	0.07	<5	7.44	33	18	20	0.1	0.02	6	0.89	0	Satisfactory
320	2083/05/16	15:45	Maharajgunj	Bansbari WTP	Treated	Clear	0.13	<5	7.37	31.2	18	20	0.1	0.02	6	0.82	0	Satisfactory
321	2083/05/16	9:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.7	<5	6.92	41.3	16	18	0.1	0.02	4	1.11	0	Satisfactory
322	2083/05/16	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1	<5	7.31	41	16	18	0.1	0.02	4	1.02	0	Satisfactory
323	2083/05/16	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.7	<5	6.76	48.6	16	18	0.1	0.02	6	1.72	0	Satisfactory
324	2083/05/16	16:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.3	<5	6.5	46.1	16	18	0.1	0.02	6	1.3	0	Satisfactory
325	2083/05/16	13:10	Baneshwor	Minbhawan SRT	Treated	Clear	0.1	<5	7.26	59.1	18	20	0.1	0.02	6	1.29	0	Satisfactory
326	2083/05/16	10:55	Mahankalchaur	NEW Mahankalchaur	Treated	Clear	1	<5	7.3	56.3	18	20	0.1	0.02	6	0.2	0	Satisfactory
327	2083/05/16	12:15	Mahankalchaur	Harijan Tole(Tilganga	Tap	Clear	1.4	<5	6.9	46.8	16	18	0.1	0.02	4	0.74	0	Satisfactory
328	2083/05/16	13:44	Maharajgunj	Dillibazar	Tap	Clear	0.4	<5	7.37	59.3	18	20	0.1	0.02	6	0.79	0	Satisfactory
329	2083/05/16	14:11	Mahankalchaur	Setopul (New Mahan	Tap	Clear	0.6	<5	7.4	57.9	18	20	0.1	0.02	6	0.14	0	Satisfactory
330	2083/05/16	13:34	Mahankalchaur	Dillibazar Kalikasthar	Tap	Clear	1.1	<5	7.13	58.9	18	20	0.1	0.02	6	0.87	0	Satisfactory
331	2083/05/16	11:48	Mahankalchaur	Tilganga(Mahankalch	Tap	Clear	1.7	<5	6.93	43.1	16	18	0.1	0.02	4	0.8	0	Satisfactory
332	2083/05/16	13:57	Mahankalchaur	Gyaneshwor	Tap	Clear	1.4	<5	7.32	58.5	18	20	0.1	0.02	6	1.41	0	Satisfactory
333	2083/05/16	9:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	1	< 5	6.57	47.9	14	16	0.1	0.02	4	1.2	0	Satisfactory
334	2083/05/16	11:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.46	< 5	6.81	42.5	14	16	0.1	0.02	4	0.67	0	Satisfactory
335	2083/05/16	13:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.4	< 5	6.82	45	14	16	0.1	0.02	4	1.39	0	Satisfactory
336	2083/05/16	15:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.81	< 5	6.85	43.7	14	16	0.1	0.02	4	1.47	0	Satisfactory
337	2083/05/16	17:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.81	< 5	6.91	43.3	14	16	0.1	0.02	4	1.34	0	Satisfactory
338	2083/05/17	9:35	Lalitpur	Sainbu W.T.P.	Treated	Clear	4.4	<5	7.85	393	94	86	0.1	0.02	18	1.5	0	Satisfactory
339	2083/05/17	13:30	Lalitpur	Sainbu W.T.P.	Treated	Clear	4.32	<5	7.82	390	90	80	0.1	0.02	18	1	0	Satisfactory
340	2083/05/17	15:55	Lalitpur	Sainbu W.T.P.	Treated	Clear	4.3	<5	7.8	388	86	76	0.1	0.02	16	0.5	0	Satisfactory
341	2083/05/17	9:30	Madhyapur Thimi	Bode WTP	Treated	Clear	2.47	<5	6.84	285	96	70	0.38	1.5	20	0.2	0	Satisfactory
342	2083/05/17	13:00	Madhyapur Thimi	Bode WTP	Treated	Clear	2.45	<5	6.95	287	96	76	0.38	1.5	20	0.16	0	Satisfactory
343	2083/05/17	15:00	Madhyapur Thimi	Bode WTP	Treated	Clear	2.6	<5	7.04	294	98	76	0.38	1.5	20	0.42	0	Satisfactory

344	2083/05/17	9:15	Madhyapur Thimi	Tigani SRT	Treated	Clear	1.92	<5	7.05	63.2	20	20	0.1	0.02	6	0.2	0	Satisfactory
345	2083/05/17	15:00	Maharajgunj	Balaju SRT	Treated	Clear	0.8	<5	7.5	56.6	18	20	0.1	0.02	6	0.2	0	Satisfactory
346	2083/05/17	9:00	Maharajgunj	Bansbari WTP	Treated	Clear	0.18	<5	7.35	30.3	18	20	0.1	0.02	6	0.86	0	Satisfactory
347	2083/05/17	13:25	Maharajgunj	Bansbari WTP	Treated	Clear	0.15	<5	7.43	27.34	18	20	0.1	0.02	6	1.04	0	Satisfactory
348	2083/05/17	15:20	Maharajgunj	Bansbari WTP	Treated	Clear	0.07	<5	7.53	28.66	18	20	0.1	0.02	6	1.02	0	Satisfactory
349	2083/05/17	13:18	Kirtipur	Kirtipur SRT	Treated	Clear	0.3	<5	7.4	67	18	20	0.1	0.02	6	0.81	0	Satisfactory
350	2083/05/17	9:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.7	<5	6.5	45.3	16	18	0.1	0.02	6	0.85	0	Satisfactory
351	2083/05/17	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	2.3	<5	7.14	48.2	16	18	0.1	0.02	6	0.98	0	Satisfactory
352	2083/05/17	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.3	<5	7.06	66.4	18	20	0.1	0.02	6	1.75	0	Satisfactory
353	2083/05/17	16:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.8	<5	7.37	56.1	18	20	0.1	0.02	6	0.9	0	Satisfactory
354	2083/05/17	10:15	Mahankalchaur	NEW Mahankalchaur	Treated	Clear	1	<5	7.77	55.4	18	20	0.1	0.02	6	0.2	0	Satisfactory
355	2083/05/17	15:30	Maharajgunj	Panipokhari outlet	Treated	Clear	1.1	<5	7.14	49.6	16	20	0.1	0.02	6	0.9	0	Satisfactory
356	2083/05/17	13:28	Kirtipur	Shivalaya (Kirtipur)	Tap	Clear	1.9	<5	7.4	66	18	20	0.1	0.02	6	1.21	0	Satisfactory
357	2083/05/17	12:10	Tripureshwor	Maitighar	Tap	Clear	0.5	<5	8.29	75.1	24	24	0.1	0.02	8	0.2	0	Satisfactory
358	2083/05/17	10:40	Mahankalchaur	Gaushala Pul	Tap	Clear	2.4	<5	7.39	50.6	18	20	0.1	0.02	6	0.83	0	Satisfactory
359	2083/05/17	11:00	Mahankalchaur	Bijay chowk (New Ma	Tap	Clear	1.1	<5	7.51	58.1	16	20	0.1	0.02	6	0.11	0	Satisfactory
360	2083/05/17	11:12	Mahankalchaur	Rayamajhi Aarogya M	Tap	Clear	0.9	<5	7.46	58.4	18	20	0.1	0.02	6	0.2	0	Satisfactory
361	2083/05/17	14:35	Maharajgunj	Shobhabhagwati Sar	Tap	Clear	1	<5	7.65	62.1	18	20	0.1	0.02	6	0.53	0	Satisfactory
362	2083/05/17	12:15	Tripureshwor	Thapathali	Tap	Clear	0.6	<5	7.83	68.7	18	20	0.1	0.02	6	0.2	0	Satisfactory
363	2083/05/17	9:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.32	< 5	6.86	43.3	14	16	0.1	0.02	4	1.52	0	Satisfactory
364	2083/05/17	11:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.41	< 5	6.95	43.8	14	16	0.1	0.02	4	1.46	0	Satisfactory
365	2083/05/17	13:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.26	< 5	6.9	44	14	16	0.1	0.02	4	1.42	0	Satisfactory
366	2083/05/17	15:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.32	< 5	7.08	43.1	14	16	0.1	0.02	4	1.11	0	Satisfactory
367	2083/05/17	17:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.29	< 5	7.04	43.6	14	16	0.1	0.02	4	1.2	0	Satisfactory
368	2083/05/17	19:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.41	< 5	7.1	44.6	14	16	0.1	0.02	4	1.11	0	Satisfactory
369	2083/05/18	9:45	Lalitpur	Sainbu W.T.P.	Treated	Clear	0.62	<5	7.89	399	100	92	0.1	0.02	16	1	0	Satisfactory
370	2083/05/18	13:40	Lalitpur	Sainbu W.T.P.	Treated	Clear	0.6	<5	7.85	395	96	88	0.1	0.02	18	0.5	0	Satisfactory

371	2083/05/18	15:45	Lalitpur	Sainbu W.T.P.	Treated	Clear	0.58	<5	7.8	392	92	84	0.1	0.02	16	0.5	0	Satisfactory
372	2083/05/18	9:30	Madhyapur Thimi	Bode WTP	Treated	Clear	3.08	<5	7.04	326	104	78	0.19	1.5	20	0.6	0	Satisfactory
373	2083/05/18	13:00	Madhyapur Thimi	Bode WTP	Treated	Clear	2.98	<5	7.03	318	102	78	0.19	1.5	20	0.56	0	Satisfactory
374	2083/05/18	15:30	Madhyapur Thimi	Bode WTP	Treated	Clear	2.66	<5	7.05	315	102	76	0.3	0.38	18	0.52	0	Satisfactory
375	2083/05/18	9:00	Maharajgunj	Bansbari WTP	Treated	Clear	0.27	<5	7.51	28.84	18	20	0.1	0.02	6	0.48	0	Satisfactory
376	2083/05/18	13:15	Maharajgunj	Bansbari WTP	Treated	Clear	0.16	<5	7.47	28.72	18	20	0.1	0.02	6	0.75	0	Satisfactory
377	2083/05/18	15:35	Maharajgunj	Bansbari WTP	Treated	Clear	0.13	<5	7.44	28.84	18	20	0.1	0.02	6	1.04	0	Satisfactory
378	2083/05/18	9:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.8	<5	6.9	45.2	16	18	0.1	0.02	6	0.68	0	Satisfactory
379	2083/05/18	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.7	<5	6.5	48.7	16	18	0.1	0.02	6	1.75	0	Satisfactory
380	2083/05/18	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.3	<5	7.1	45	16	18	0.1	0.02	6	1.62	0	Satisfactory
381	2083/05/18	16:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.1	<5	7.14	45.8	16	18	0.1	0.02	6	1.51	0	Satisfactory
382	2083/05/18	13:36	Mahankalchaur	Maligau (Mahankalchaur)	Tap	Clear	0.7	<5	7.02	47.7	16	18	0.1	0.02	6	0.85	0	Satisfactory
383	2083/05/18	12:38	Mahankalchaur	Hira Ratna Hall(Kalopul)	Tap	Clear	0.1	<5	7.02	46.5	16	20	0.1	0.02	4	0.85	0	Satisfactory
384	2083/05/18	11:19	Mahankalchaur	Suniti Marga, Sinamarga	Tap	Clear	0.3	<5	7.4	61.5	18	20	0.1	0.02	6	0.77	0	Satisfactory
385	2083/05/18	13:30	Mahankalchaur	Bhatkekopul, Sinamarga	Tap	Clear	0.1	<5	7.27	64.2	20	20	0.1	0.02	6	0.89	0	Satisfactory
386	2083/05/18	12:29	Mahankalchaur	Sifal Oralo (Mahankalchaur)	Tap	Clear	0.5	<5	7.26	46	16	18	0.1	0.02	4	0.66	0	Satisfactory
387	2083/05/18	10:42	Mahankalchaur	Shambhu Marga , Aikya	Tap	Clear	0.1	<5	7.29	65.2	18	20	0.1	0.02	6	0.75	0	Satisfactory
388	2083/05/18	10:27	Mahankalchaur	Tilganga (New Mahankalchaur)	Tap	Clear	0.4	<5	7.33	63.5	18	20	0.1	0.02	6	0.2	0	Satisfactory
389	2083/05/18	13:45	Mahankalchaur	Kalopul	Tap	Clear	2.4	<5	7.09	47.5	16	18	0.1	0.02	4	0.51	0	Satisfactory
390	2083/05/18	9:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.63	< 5	6.54	50.2	14	16	0.1	0.02	4	1.5	0	Satisfactory
391	2083/05/18	11:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.54	< 5	6.59	47.9	14	16	0.1	0.02	4	1.41	0	Satisfactory
392	2083/05/18	13:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.7	< 5	6.66	47.3	14	16	0.1	0.02	4	1.47	0	Satisfactory
393	2083/05/18	15:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	1.8	< 5	6.97	44.2	14	16	0.1	0.02	4	1.14	0	Satisfactory
394	2083/05/18	17:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.31	< 5	6.82	45.2	14	16	0.1	0.02	4	1.53	0	Satisfactory
395	2083/05/18	19:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.91	< 5	7.09	44.9	14	16	0.1	0.02	4	1.14	0	Satisfactory
396	2083/05/19	9:00	Maharajgunj	Bansbari WTP	Treated	Clear	0.17	<5	6.5	28.74	18	20	0.1	0.02	6	1.02	0	Satisfactory
397	2083/05/19	13:15	Maharajgunj	Bansbari WTP	Treated	Clear	0.13	<5	7.58	27.52	18	20	0.1	0.02	6	0.66	0	Satisfactory

398	2083/05/19	15:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.1	<5	7.47	52.9	18	20	0.1	0.02	6	1.31	0	Satisfactory
399	2083/05/19	10:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.27	< 5	6.94	47	14	16	0.1	0.02	4	1.51	0	Satisfactory
400	2083/05/19	13:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.34	< 5	6.99	44.9	14	16	0.1	0.02	4	1.26	0	Satisfactory
401	2083/05/19	17:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.39	< 5	6.89	43.7	14	16	0.1	0.02	4	1.35	0	Satisfactory
402	2083/05/20	9:00	Maharajgunj	Bansbari WTP	Treated	Clear	0.34	<5	7.47	26.76	18	20	0.1	0.02	6	0.42	0	Satisfactory
403	2083/05/20	13:00	Maharajgunj	Bansbari WTP	Treated	Clear	0.24	<5	7.42	34.2	18	20	0.1	0.02	6	1.47	0	Satisfactory
404	2083/05/20	15:45	Maharajgunj	Bansbari WTP	Treated	Clear	0.18	<5	7.52	27.07	18	20	0.1	0.02	6	0.93	0	Satisfactory
405	2083/05/20	15:30	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.1	<5	6.9	49.7	16	18	0.1	0.02	6	1.35	0	Satisfactory
406	2083/05/20	10:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.23	< 5	6.97	49.9	14	16	0.1	0.02	4	1.44	0	Satisfactory
407	2083/05/20	12:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.31	< 5	6.87	49.7	14	16	0.1	0.02	4	1.52	0	Satisfactory
408	2083/05/20	14:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.42	< 5	6.99	45.5	14	16	0.1	0.02	4	1.21	0	Satisfactory
409	2083/05/20	17:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.36	< 5	6.99	44.2	14	16	0.1	0.02	4	1.48	0	Satisfactory
410	2083/05/21	11:50	Maharajgunj	Bansbari WTP	Treated	Clear	0.32	<5	7.62	32.4	18	20	0.1	0.02	6	1.05	0	Satisfactory
411	2083/05/21	14:15	Maharajgunj	Bansbari WTP	Treated	Clear	0.24	<5	7.75	35.4	18	20	0.1	0.02	6	1.15	0	Satisfactory
412	2083/05/21	15:35	Maharajgunj	Bansbari WTP	Treated	Clear	0.15	<5	7.65	34	18	20	0.1	0.02	6	1.11	0	Satisfactory
413	2083/05/21	15:15	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.4	<5	6.68	55.2	18	20	0.1	0.02	6	1.27	0	Satisfactory
414	2083/05/21	10:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.17	< 5	6.64	45.2	14	16	0.1	0.02	4	1.39	0	Satisfactory
415	2083/05/21	12:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.18	< 5	6.61	43.3	14	16	0.1	0.02	4	1.48	0	Satisfactory
416	2083/05/21	14:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.19	< 5	6.82	42.3	14	16	0.1	0.02	4	1.31	0	Satisfactory
417	2083/05/21	17:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.27	< 5	6.81	42.6	14	16	0.1	0.02	4	1.54	0	Satisfactory
418	2083/05/22	9:35	Lalitpur	Sainbu W.T.P.	Treated	Clear	2.35	<5	7.9	388	90	86	0.1	0.02	18	1.5	0	Satisfactory
419	2083/05/22	13:40	Lalitpur	Sainbu W.T.P.	Treated	Clear	2.3	<5	7.85	385	86	80	0.1	0.02	16	1	0	Satisfactory
420	2083/05/22	15:40	Lalitpur	Sainbu W.T.P.	Treated	Clear	2.15	<5	7.8	380	82	76	0.1	0.02	18	0.5	0	Satisfactory
421	2083/05/22	9:30	Madhyapur Thimi	Bode WTP	Treated	Clear	2.76	<5	7.04	278	96	76	0.3	0.38	18	0.52	0	Satisfactory
422	2083/05/22	13:00	Madhyapur Thimi	Bode WTP	Treated	Clear	3.04	<5	7.15	303	102	78	0.3	0.19	18	0.9	0	Satisfactory
423	2083/05/22	15:00	Madhyapur Thimi	Bode WTP	Treated	Clear	2.81	<5	7.14	296	102	78	0.3	0.19	18	0.46	0	Satisfactory
424	2083/05/22	8:00	Madhyapur Thimi	Tigani SRT	Treated	Clear	2.42	<5	7.6	49.7	16	18	0.02	0.1	6	0.2	0	Satisfactory

425	2083/05/22	9:15	Maharajgunj	Bansbari WTP	Treated	Clear	0.22	<5	7.56	29.54	18	20	0.1	0.02	6	0.52	0	Satisfactory
426	2083/05/22	13:00	Maharajgunj	Bansbari WTP	Treated	Clear	0.18	<5	7.53	29.66	18	20	0.1	0.02	6	0.74	0	Satisfactory
427	2083/05/22	14:55	Maharajgunj	Bansbari WTP	Treated	Clear	0.13	<5	7.63	30.1	18	20	0.1	0.02	6	1.04	0	Satisfactory
428	2083/05/22	9:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.8	<5	6.78	55.8	18	20	0.1	0.02	6	1.15	0	Satisfactory
429	2083/05/22	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.3	<5	8.44	90.7	20	24	0.1	0.02	10	1.9	0	Satisfactory
430	2083/05/22	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.1	<5	7.09	80.9	18	22	0.1	0.02	8	0.57	0	Satisfactory
431	2083/05/22	16:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.4	<5	7.12	68.8	18	20	0.1	0.02	6	1	0	Satisfactory
432	2083/05/22	12:29	Mahankalchaur	Kalopul	Tap	Clear	0.4	<5	7.27	52.1	18	18	0.1	0.02	6	0.71	0	Satisfactory
433	2083/05/22	12:44	Baneshwor	Ghattekulo Marga	Tap	Clear	0.3	<5	7.4	64.7	18	20	0.1	0.02	8	0.47	0	Satisfactory
434	2083/05/22	11:30	Maharajgunj	Putalisadak (New Ma	Tap	Clear	0.5	<5	7.2	69.3	20	22	0.1	0.02	6	0.3	0	Satisfactory
435	2083/05/22	10:46	Mahankalchaur	Sanogaucharan (Ma	Tap	Clear	0.4	<5	7.24	62.1	18	20	0.1	0.02	6	0.21	0	Satisfactory
436	2083/05/22	14:01	Mahankalchaur	Hadigao (Mahankalc	Tap	Clear	0.9	<5	6.5	71.4	18	20	0.1	0.02	6	1.28	0	Satisfactory
437	2083/05/22	12:24	Maharajgunj	Dillibazar	Tap	Clear	0.3	<5	7.31	65.7	18	20	0.1	0.02	8	0.27	0	Satisfactory
438	2083/05/22	10:20	Mahankalchaur	Hira Ratna Hall(Kalc	Tap	Clear	0.32	<5	7.14	67.5	18	20	0.1	0.02	6	0.15	0	Satisfactory
439	2083/05/22	11:45	Mahankalchaur	Dillibazar Kalikastha	Tap	Clear	0.33	<5	7.3	67.3	20	22	0.1	0.02	6	0.73	0	Satisfactory
440	2083/05/22	9:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.82	< 5	6.84	44	14	16	0.1	0.02	4	1.5	0	Satisfactory
441	2083/05/22	11:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.98	< 5	6.89	43.2	14	16	0.1	0.02	4	1.38	0	Satisfactory
442	2083/05/22	13:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.87	< 5	6.85	44	14	16	0.1	0.02	4	1.36	0	Satisfactory
443	2083/05/22	15:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.57	< 5	6.51	43.6	14	16	0.1	0.02	4	1.42	0	Satisfactory
444	2083/05/22	17:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.59	< 5	6.55	43.4	14	16	0.1	0.02	4	1.4	0	Satisfactory
445	2083/05/22	19:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	2.24	< 5	6.64	44.7	14	16	0.1	0.02	4	1.14	0	Satisfactory
446	2083/05/23	8:45	Maharajgunj	Bansbari WTP	Treated	Clear	0.17	<5	7.55	29.94	18	20	0.1	0.02	6	0.62	0	Satisfactory
447	2083/05/23	12:55	Maharajgunj	Bansbari WTP	Treated	Clear	0.13	<5	7.65	33.4	18	20	0.1	0.02	6	1.21	0	Satisfactory
448	2083/05/23	15:10	Maharajgunj	Bansbari WTP	Treated	Clear	0.08	<5	7.62	30.6	18	20	0.1	0.02	6	0.86	0	Satisfactory
449	2083/05/23	15:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.8	<5	6.98	55.5	18	20	0.1	0.02	6	1.14	0	Satisfactory
450	2083/05/23	10:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.49	< 5	6.69	45.2	14	16	0.1	0.02	4	1.46	0	Satisfactory
451	2083/05/23	12:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.5	< 5	6.85	45.8	14	16	0.1	0.02	4	1.39	0	Satisfactory

452	2083/05/23	14:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.45	< 5	6.93	42.8	14	16	0.1	0.02	4	1.56	0	Satisfactory
453	2083/05/23	17:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.31	< 5	6.91	43.1	14	16	0.1	0.02	4	1.35	0	Satisfactory
454	2083/05/24	9:55	Lalitpur	Sainbu W.T.P.	Treated	Clear	0.95	<5	7.88	395	96	90	0.1	0.02	16	1.9	0	Satisfactory
455	2083/05/24	13:30	Lalitpur	Sainbu W.T.P.	Treated	Clear	0.9	<5	7.85	390	90	82	0.1	0.02	18	1.5	0	Satisfactory
456	2083/05/24	15:50	Lalitpur	Sainbu W.T.P.	Treated	Clear	0.88	<5	7.8	386	86	80	0.1	0.02	16	1	0	Satisfactory
457	2083/05/24	9:30	Madhyapur Thimi	Bode WTP	Treated	Clear	2.91	<5	7.07	302	102	76	0.3	0.19	18	0.3	0	Satisfactory
458	2083/05/24	13:00	Madhyapur Thimi	Bode WTP	Treated	Clear	2.88	<5	7.06	294.1	100	76	0.3	0.19	18	0.29	0	Satisfactory
459	2083/05/24	15:00	Madhyapur Thimi	Bode WTP	Treated	Clear	2.94	<5	7.05	292.7	100	76	0.3	0.19	18	0.21	0	Satisfactory
460	2083/05/24	15:10	Maharajgunj	Bansbari WTP	Treated	Clear	0.15	<5	7.58	39.2	18	20	0.1	0.02	6	1.25	0	Satisfactory
461	2083/05/24	16:10	Maharajgunj	Bansbari WTP	Treated	Clear	0.23	<5	7.55	36.7	18	20	0.1	0.02	6	1.15	0	Satisfactory
462	2083/05/24	12:45	Kirtipur	Kirtipur SRT	Treated	Clear	0.2	<5	7.6	67.7	18	20	0.1	0.02	6	1.25	0	Satisfactory
463	2083/05/24	9:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.4	<5	6.5	44.9	14	16	0.1	0.02	6	1.26	0	Satisfactory
464	2083/05/24	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.2	<5	6.81	52.5	18	20	0.1	0.02	6	1.44	0	Satisfactory
465	2083/05/24	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.7	<5	7.4	46.9	18	20	0.1	0.02	6	1.34	0	Satisfactory
466	2083/05/24	16:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.2	<5	7.2	54.9	18	22	0.1	0.02	6	1.27	0	Satisfactory
467	2083/05/24	10:16	Mahankalchaur	NEW Mahankalchaur	Treated	Clear	2.4	<5	7.45	62	18	22	0.1	0.02	6	0.8	0	Satisfactory
468	2083/05/24	15:40	Maharajgunj	Panipokhari outlet	Treated	Clear	0.8	<5	6.68	51.8	18	20	0.1	0.02	6	0.21	0	Satisfactory
469	2083/05/24	10:48	Mahankalchaur	Shambhu Marga (Ne	Tap	Clear	0.6	<5	7.55	67.6	18	20	0.1	0.02	6	1.19	0	Satisfactory
470	2083/05/24	11:24	Mahankalchaur	Baburam Acharya Ma	Tap	Clear	0.8	<5	7.6	68.4	20	22	0.1	0.02	8	0.85	0	Satisfactory
471	2083/05/24	11:16	Mahankalchaur	Bhatkekopul, Sinama	Tap	Clear	0.5	<5	7.53	67.8	22	20	0.1	0.02	8	1.03	0	Satisfactory
472	2083/05/24	10:59	Mahankalchaur	Ashram Marga Tilgar	Tap	Clear	1	<5	7.1	67.8	18	22	0.1	0.02	8	1.38	0	Satisfactory
473	2083/05/24	13:50	Kirtipur	Lampati Chitij School	Tap	Clear	1.3	<5	7.37	78.5	18	20	0.1	0.02	8	1.3	0	Satisfactory
474	2083/05/24	9:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.31	< 5	6.84	42.8	14	16	0.1	0.02	4	1.48	0	Satisfactory
475	2083/05/24	11:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.29	< 5	6.85	42.9	14	16	0.1	0.02	4	1.42	0	Satisfactory
476	2083/05/24	13:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.38	< 5	6.84	42	14	16	0.1	0.02	4	1.37	0	Satisfactory
477	2083/05/24	15:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.46	< 5	6.94	42.5	14	16	0.1	0.02	4	1.49	0	Satisfactory
478	2083/05/24	17:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.51	< 5	6.96	42.6	14	16	0.1	0.02	4	1.41	0	Satisfactory

479	2083/05/24	19:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.39	< 5	6.94	43.6	14	16	0.1	0.02	4	1.14	0	Satisfactory
480	2083/05/25	9:30	Lalitpur	Sainbu W.T.P.	Treated	Clear	0.85	<5	7.86	399	100	92	0.1	0.02	18	1.5	0	Satisfactory
481	2083/05/25	9:30	Madhyapur Thimi	Bode WTP	Treated	Clear	3.18	<5	7.02	278	98	70	0.3	0.38	18	0.2	0	Satisfactory
482	2083/05/25	13:00	Madhyapur Thimi	Bode WTP	Treated	Clear	2.97	<5	6.99	283	98	76	0.3	0.19	18	0.36	0	Satisfactory
483	2083/05/25	12:24	Maharajgunj	Balaju SRT	Treated	Clear	0.3	<5	6.63	61.5	18	20	0.1	0.02	6	0.2	0	Satisfactory
484	2083/05/25	9:00	Maharajgunj	Bansbari WTP	Treated	Clear	0.28	<5	7.43	31.4	18	20	0.1	0.02	6	0.82	0	Satisfactory
485	2083/05/25	13:35	Maharajgunj	Bansbari WTP	Treated	Clear	0.16	<5	7.58	29.76	18	20	0.1	0.02	6	1.02	0	Satisfactory
486	2083/05/25	15:15	Maharajgunj	Bansbari WTP	Treated	Clear	0.13	<5	7.47	30.1	18	20	0.1	0.02	6	1.05	0	Satisfactory
487	2083/05/25	14:10	Kirtipur	Kirtipur SRT	Treated	Clear	0.3	<5	6.72	68.7	18	20	0.1	0.02	6	1.73	0	Satisfactory
488	2083/05/25	9:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	3.3	<5	7.2	47.1	16	20	0.1	0.02	6	0.78	0	Satisfactory
489	2083/05/25	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.5	<5	6.63	46.6	16	20	0.1	0.02	6	1.15	0	Satisfactory
490	2083/05/25	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	4.9	<5	6.5	49	16	20	0.1	0.02	6	1.01	0	Satisfactory
491	2083/05/25	16:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.5	<5	6.82	43.6	16	20	0.1	0.02	6	0.88	0	Satisfactory
492	2083/05/25	10:20	Mahankalchaur	NEW Mahankalchaur	Treated	Clear	0.6	<5	7.37	61.8	18	22	0.1	0.02	6	1.38	0	Satisfactory
493	2083/05/25	11:50	Maharajgunj	Panipokhari outlet	Treated	Clear	0.2	<5	7.62	49.4	16	20	0.1	0.02	6	0.55	0	Satisfactory
494	2083/05/25	10:47	Mahankalchaur	Hira Ratna Hall(Kalodaha)	Tap	Clear	0.9	<5	7.2	45.9	16	20	0.1	0.02	4	0.36	0	Satisfactory
495	2083/05/25	11:07	Mahankalchaur	Dhungedhara (Mahankalchaur)	Tap	Clear	0.8	<5	7.28	45.9	16	18	0.1	0.02	4	0.29	0	Satisfactory
496	2083/05/25	13:24	Kirtipur	Shrestha Colony, Bagmati	Tap	Clear	0.1	<5	7.45	70.4	18	20	0.1	0.02	6	1.55	0	Satisfactory
497	2083/05/25	13:15	Kirtipur	Bijaychowk (Kirtipur)	Tap	Clear	0.4	<5	6.98	69.7	20	22	0.1	0.02	8	0.71	0	Satisfactory
498	2083/05/25	9:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.12	< 5	6.72	45.7	14	16	0.1	0.02	4	1.42	0	Satisfactory
499	2083/05/25	11:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.24	< 5	6.76	43.7	14	16	0.1	0.02	4	1.31	0	Satisfactory
500	2083/05/25	13:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.32	< 5	6.81	43.2	14	16	0.1	0.02	4	1.35	0	Satisfactory
501	2083/05/25	15:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.48	< 5	6.91	43.4	14	16	0.1	0.02	4	1.21	0	Satisfactory
502	2083/05/25	17:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.33	< 5	6.84	43.6	14	16	0.1	0.02	4	1.4	0	Satisfactory
503	2083/05/26	9:45	Lalitpur	Sainbu W.T.P.	Treated	Clear	3.85	<5	7.86	392	94	86	0.1	0.02	18	1.5	0	Satisfactory
504	2083/05/26	13:55	Lalitpur	Sainbu W.T.P.	Treated	Clear	3.8	<5	7.8	388	90	82	0.1	0.02	16	1	0	Satisfactory
505	2083/05/26	15:50	Lalitpur	Sainbu W.T.P.	Treated	Clear	3.77	<5	7.75	385	86	80	0.1	0.02	18	0.5	0	Satisfactory

506	2083/05/26	9:30	Madhyapur Thimi	Bode WTP	Treated	Clear	3.12	<5	7.02	279	98	72	0.3	0.19	18	0.12	0	Satisfactory
507	2083/05/26	12:30	Madhyapur Thimi	Bode WTP	Treated	Clear	3.5	<5	7.24	321	104	78	0.3	0.19	18	1.15	0	Satisfactory
508	2083/05/26	15:30	Madhyapur Thimi	Bode WTP	Treated	Clear	2.88	<5	7.2	313	102	78	0.3	0.19	18	0.79	0	Satisfactory
509	2083/05/26	9:00	Maharajgunj	Bansbari WTP	Treated	Clear	0.19	<5	7.51	35	18	20	0.1	0.02	6	1.07	0	Satisfactory
510	2083/05/26	13:00	Maharajgunj	Bansbari WTP	Treated	Clear	0.15	<5	7.54	34.2	18	20	0.1	0.02	6	1.02	0	Satisfactory
511	2083/05/26	15:25	Maharajgunj	Bansbari WTP	Treated	Clear	0.18	<5	7.61	33	18	20	0.1	0.02	6	1.11	0	Satisfactory
512	2083/05/26	12:40	Lalitpur	Khumaltar SRT	Treated	Clear	1.9	<5	7.49	68.8	18	22	0.1	0.02	8	0.96	0	Satisfactory
513	2083/05/26	13:35	Kirtipur	Kirtipur SRT	Treated	Clear	0.7	<5	7.5	73.7	22	24	0.1	0.02	8	1.06	0	Satisfactory
514	2083/05/26	9:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.8	<5	7.03	43.8	16	20	0.1	0.02	6	1.07	0	Satisfactory
515	2083/05/26	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.8	<5	6.77	41	14	20	0.1	0.02	6	0.79	0	Satisfactory
516	2083/05/26	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.4	<5	7.1	49.7	16	20	0.1	0.02	6	0.76	0	Satisfactory
517	2083/05/26	16:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.8	<5	7.36	56.6	18	22	0.1	0.02	8	0.33	0	Satisfactory
518	2083/05/26	14:10	Baneshwor	Minbhawan SRT	Treated	Clear	1.4	<5	7.4	62.4	18	22	0.1	0.02	6	0.2	0	Satisfactory
519	2083/05/26	11:20	Mahankalchaur	Harijan Tole(Tilganga	Tap	Clear	2	<5	7.5	46.2	16	18	0.1	0.02	4	0.22	0	Satisfactory
520	2083/05/26	15:30	Mahankalchaur	Devkota Marga (New	Tap	Clear	3	<5	7.41	45.1	16	18	0.1	0.02	4	0.49	0	Satisfactory
521	2083/05/26	10:54	Mahankalchaur	Gaurighat	Tap	Clear	2.4	<5	7.46	46.1	16	20	0.1	0.02	6	0.2	0	Satisfactory
522	2083/05/26	14:54	Mahankalchaur	Shrijiti Marga, Shanti	Tap	Clear	0.7	<5	7.53	66.9	18	20	0.1	0.02	6	0.55	0	Satisfactory
523	2083/05/26	11:39	Lalitpur	Madan Bhandari Park	Tap	Clear	0.2	<5	7.6	72	18	20	0.1	0.02	8	0.98	0	Satisfactory
524	2083/05/26	11:09	Mahankalchaur	Harijan Tole(Tilganga	Tap	Clear	0.7	<5	7.5	47	16	18	0.1	0.02	4	0.11	0	Satisfactory
525	2083/05/26	11:45	Lalitpur	Samparka Marga, Kc	Tap	Clear	0.2	<5	7.4	68.8	18	20	0.1	0.02	6	0.74	0	Satisfactory
526	2083/05/26	10:42	Mahankalchaur	Maijugal, Gaurighat	Tap	Clear	2.3	<5	7.4	46.5	16	18	0.1	0.02	6	0.37	0	Satisfactory
527	2083/05/26	9:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.32	< 5	6.8	47.3	14	16	0.1	0.02	4	1.55	0	Satisfactory
528	2083/05/26	11:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.29	< 5	7.12	45.5	14	16	0.1	0.02	4	1.38	0	Satisfactory
529	2083/05/26	13:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.33	< 5	6.91	46.1	14	16	0.1	0.02	4	1.15	0	Satisfactory
530	2083/05/26	15:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.39	< 5	6.84	47.8	14	16	0.1	0.02	4	1.44	0	Satisfactory
531	2083/05/26	17:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.26	< 5	6.97	44.9	14	16	0.1	0.02	4	1.31	0	Satisfactory
532	2083/05/27	11:00	Maharajgunj	Bansbari WTP	Treated	Clear	0.28	<5	7.54	33.4	18	20	0.1	0.02	6	0.82	0	Satisfactory

533	2083/05/27	14:25	Maharajgunj	Bansbari WTP	Treated	Clear	0.18	<5	7.64	37.2	18	20	0.1	0.02	6	1.13	0	Satisfactory
534	2083/05/27	15:35	Maharajgunj	Bansbari WTP	Treated	Clear	0.13	<5	7.57	35	18	20	0.1	0.02	6	1.07	0	Satisfactory
535	2083/05/27	10:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.27	< 5	6.89	45.2	14	16	0.1	0.02	4	1.42	0	Satisfactory
536	2083/05/27	12:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.31	< 5	6.9	47.1	14	16	0.1	0.02	4	1.54	0	Satisfactory
537	2083/05/27	14:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.24	< 5	6.86	48.5	14	16	0.1	0.02	4	1.48	0	Satisfactory
538	2083/05/27	17:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.36	< 5	6.91	42.7	14	16	0.1	0.02	4	1.09	0	Satisfactory
539	2083/05/28	9:00	Maharajgunj	Bansbari WTP	Treated	Clear	0.15	<5	7.53	33.2	18	20	0.1	0.02	6	1.03	0	Satisfactory
540	2083/05/28	16:15	Maharajgunj	Bansbari WTP	Treated	Clear	0.11	<5	7.55	31.2	18	20	0.1	0.02	6	1.05	0	Satisfactory
541	2083/05/28	9:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.39	< 5	6.76	44.9	14	16	0.1	0.02	4	1.49	0	Satisfactory
542	2083/05/28	12:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.31	< 5	7.16	43.5	14	16	0.1	0.02	4	1.08	0	Satisfactory
543	2083/05/28	14:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.4	< 5	7.02	43.7	14	16	0.1	0.02	4	1.45	0	Satisfactory
544	2083/05/29	9:35	Lalitpur	Sainbu W.T.P.	Treated	Clear	4.5	<5	7.94	395	96	88	0.1	0.02	16	1	0	Satisfactory
545	2083/05/29	13:45	Lalitpur	Sainbu W.T.P.	Treated	Clear	4	<5	7.89	390	90	82	0.1	0.02	18	1	0	Satisfactory
546	2083/05/29	15:50	Lalitpur	Sainbu W.T.P.	Treated	Clear	3.5	<5	7.87	385	86	80	0.1	0.02	16	0.5	0	Satisfactory
547	2083/05/29	9:50	Maharajgunj	Bansbari WTP	Treated	Clear	0.22	<5	7.63	30.6	18	20	0.1	0.02	6	0.61	0	Satisfactory
548	2083/05/29	13:25	Maharajgunj	Bansbari WTP	Treated	Clear	0.17	<5	7.54	29.92	18	20	0.1	0.02	6	0.84	0	Satisfactory
549	2083/05/29	15:15	Maharajgunj	Bansbari WTP	Treated	Clear	0.14	<5	7.58	30.3	18	20	0.1	0.02	6	1.02	0	Satisfactory
550	2083/05/29	11:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	1.12	< 5	6.72	54.6	14	16	0.1	0.02	4	1.55	0	Satisfactory
551	2083/05/29	18:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	1.07	< 5	7.1	45.9	14	16	0.1	0.02	4	1.56	0	Satisfactory
552	2083/05/30	9:45	Lalitpur	Sainbu W.T.P.	Treated	Clear	0.95	<5	7.9	393	94	86	0.1	0.02	16	1.5	0	Satisfactory
553	2083/05/30	13:55	Lalitpur	Sainbu W.T.P.	Treated	Clear	0.9	<5	7.88	390	90	84	0.1	0.02	18	1	0	Satisfactory
554	2083/05/30	15:45	Lalitpur	Sainbu W.T.P.	Treated	Clear	0.85	<5	7.85	388	86	80	0.1	0.02	16	1	0	Satisfactory
555	2083/05/30	9:30	Madhyapur Thimi	Bode WTP	Treated	Clear	0.98	<5	7.1	283	98	76	0.3	0.19	18	0.65	0	Satisfactory
556	2083/05/30	12:30	Madhyapur Thimi	Bode WTP	Treated	Clear	0.86	<5	7.08	288.7	98	78	0.3	0.19	18	0.73	0	Satisfactory
557	2083/05/30	15:30	Madhyapur Thimi	Bode WTP	Treated	Clear	0.8	<5	6.99	284	98	78	0.3	0.19	18	0.38	0	Satisfactory
558	2083/05/30	14:15	Maharajgunj	Balaju SRT	Treated	Clear	0.5	<5	7.1	69.3	20	20	0.1	0.02	8	0.2	0	Satisfactory
559	2083/05/30	9:25	Maharajgunj	Bansbari WTP	Treated	Clear	0.29	<5	7.51	30	18	20	0.1	0.02	6	1.04	0	Satisfactory

560	2083/05/30	12:50	Maharajgunj	Bansbari WTP	Treated	Clear	0.18	<5	7.66	30.5	18	20	0.1	0.02	6	1.11	0	Satisfactory
561	2083/05/30	14:50	Maharajgunj	Bansbari WTP	Treated	Clear	0.13	<5	7.63	33.2	18	20	0.1	0.02	6	1.06	0	Satisfactory
562	2083/05/30	9:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	1.7	<5	7.14	44	16	20	0.1	0.02	6	0.78	0	Satisfactory
563	2083/05/30	12:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.2	<5	7.25	67.1	18	20	0.1	0.02	8	1.9	0	Satisfactory
564	2083/05/30	14:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.5	<5	6.98	56.4	18	20	0.1	0.02	6	1.65	0	Satisfactory
565	2083/05/30	16:00	Mahankalchaur	Mahankalchaur WTP	Treated	Clear	0.3	<5	8.01	63.8	18	20	0.1	0.02	8	0.89	0	Satisfactory
566	2083/05/30	14:49	Maharajgunj	Ramghat (Balaju)	Tap	Clear	0.8	<5	7.53	75.5	24	26	0.1	0.02	8	0.65	0	Satisfactory
567	2083/05/30	14:40	Maharajgunj	Tamsipakha(Balaju)	Treated	Clear	1.8	<5	7.54	75.3	22	24	0.1	0.02	8	0.45	0	Satisfactory
568	2083/05/30	10:50	Mahankalchaur	New Mahankal	Tap	Clear	1.3	<5	7.71	69.2	18	22	0.1	0.02	6	0.2	0	Satisfactory
569	2083/05/30	11:30	Mahankalchaur	Prakash Nanda Marg	Tap	Clear	0.2	<5	7.74	76.5	24	26	0.1	0.02	8	1.09	0	Satisfactory
570	2083/05/30	12:40	Lalitpur	Khumaltar Sunakoti	Tap	Clear	0.5	<5	6.89	75.6	20	24	0.1	0.02	8	1.05	0	Satisfactory
571	2083/05/30	11:42	Mahankalchaur	Bhatkekopul, Sinama	Tap	Clear	0.1	<5	7.79	77.4	22	24	0.1	0.02	8	1.19	0	Satisfactory
572	2083/05/30	11:58	Mahankalchaur	Baburam Acharya Ma	Tap	Clear	0.9	<5	6.85	75.8	18	24	0.1	0.02	8	0.95	0	Satisfactory
573	2083/05/30	13:28	Kirtipur	Kirtipur SRT	Tap	Clear	0.5	<5	6.83	75.8	22	24	0.1	0.02	8	1.19	0	Satisfactory
574	2083/05/30	11:19	Mahankalchaur	Shambhu Marga, Air	Tap	Clear	1.1	<5	7.86	88.8	22	24	0.1	0.02	8	1	0	Satisfactory
575	2083/05/30	9:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.38	< 5	6.93	48.2	14	16	0.1	0.02	4	1.3	0	Satisfactory
576	2083/05/30	11:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.42	< 5	6.97	47.6	14	16	0.1	0.02	4	1.42	0	Satisfactory
577	2083/05/30	13:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.52	< 5	7.05	45.9	14	16	0.1	0.02	4	1.41	0	Satisfactory
578	2083/05/30	15:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.44	< 5	7.01	44.4	14	16	0.1	0.02	4	1.16	0	Satisfactory
579	2083/05/30	17:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.51	< 5	7.29	45.2	14	16	0.1	0.02	4	1.16	0	Satisfactory
580	2083/05/31	9:50	Lalitpur	Sainbu W.T.P.	Treated	Clear	1.8	<5	7.94	398	98	92	0.1	0.02	16	1.9	0	Satisfactory
581	2083/05/31	13:45	Lalitpur	Sainbu W.T.P.	Treated	Clear	1.78	<5	7.9	393	94	88	0.1	0.02	18	1.5	0	Satisfactory
582	2083/05/31	15:50	Lalitpur	Sainbu W.T.P.	Treated	Clear	1.75	<5	7.85	390	90	82	0.1	0.02	16	1	0	Satisfactory
583	2083/05/31	9:30	Madhyapur Thimi	Bode WTP	Treated	Clear	0.95	<5	7.06	287	98	76	0.3	0.19	18	0.43	0	Satisfactory
584	2083/05/31	12:30	Madhyapur Thimi	Bode WTP	Treated	Clear	3	<5	7.4	338	110	78	0.3	0.19	18	1.9	0	Satisfactory
585	2083/05/31	9:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.61	< 5	7.26	44.6	14	16	0.1	0.02	4	1.19	0	Satisfactory
586	2083/05/31	11:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.32	< 5	6.9	49	14	16	0.1	0.02	4	1.55	0	Satisfactory

587	2083/05/31	13:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.18	< 5	7.12	47.5	14	16	0.1	0.02	4	1.21	0	Satisfactory
588	2083/05/31	15:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.22	< 5	6.95	49.7	14	16	0.1	0.02	4	1.2	0	Satisfactory
589	2083/05/31	17:00	Sundarijal WTP Section	New Sundarijal WTP	Clear	Clear	0.26	< 5	7.01	47.8	14	16	0.1	0.02	4	1.03	0	Satisfactory